

## **North Shore Water Reclamation District Notes:**

1. The contractor shall notify both the North Shore Water Reclamation District and the municipality within whose boundaries the proposed sanitary sewer construction will take place a minimum of 24 hours prior to the start of construction. The North Shore Water Reclamation District can be notified by phone at 847-623-6060.
2. All sanitary sewer pipe shall be bedded, with a minimum of 6" below the pipe and 12" above the pipe, in CA-6 crushed material. CA-7 may be allowed at the discretion of the North Shore Water Reclamation District if extremely wet conditions are encountered.
3. The connection to downstream sewers shall be plugged with a water tight concrete plug and maintained in place until connection is approved by the North Shore Reclamation District.
4. All sanitary sewer extensions shall be televised in the presence of North Shore Reclamation District personnel after having notified the District a minimum of 24 hours prior to televising by phone at 847-623-6060. A copy of the televised sewer extension, in electronic format, shall be submitted to the District for approval.
5. All sanitary sewer extensions shall be subject to an infiltration test under the supervision of and witnessed by the District. Infiltration/ exfiltration testing shall be performed by applicable water or air testing and shall meet the minimum requirements of the latest edition of the *Standard Specifications for Water and Sewer Main Construction in Illinois*.
6. Any existing service lateral that is completely replaced or any newly installed lateral shall be made locatable by electromagnetic or other equally effective means for marking the location of the service lateral.